



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130346, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:L, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Passed	Thursday, May 23, 2013

Gas Piping Inspection - Commercial	John Borns	Partial	Thursday, May 23, 2013
---	------------	---------	------------------------

Corrective Action Required

1 MISC

TWO SUPPORTS TO BE ADDED AT ROOFTOP GAS PIPING

Corrective Action Required

2 MISC

ADDRESS I.D. TAG TO BE CORRECTED TO 860 **L**.

Comments: RELEASE GAS SERVICE.