



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20130346
Address: 860 NW BLUE PKWY, Unit:L, LEES SUMMIT, MO 64086
Inspected On: Wednesday, June 05, 2013
Inspected By: John BornsJoe DirJoe Dir
Expiration Date: 6/13/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Wednesday, June 05, 2013

Corrective Action Required:

1	MISC	OK FOR TEMP OCCUPANCY PENDING RESOLUTION OF: 1) SUPPORT ROOFTOP GAS PIPING WITHIN 18" OF 90 DEGREE BEND POINTED OUT. 2) PAINT EXPOSED GAS PIPING AT METER BANK 3) MAX HEIGHT FOR BOTTOM OF MIRROR GLASS AT ACCESSIBLE RESTROOM IS 40". 4) HEIGHT OF ACCESSIBLE RESTROOM SIGN IS 5'-0" TO CENTER.
---	------	--

Occupancy Inspection - Fire	Joe Dir	Passed	Wednesday, June 05, 2013
------------------------------------	---------	--------	--------------------------

Alarm Test	Joe Dir	Passed	Wednesday, June 05,
-------------------	---------	--------	---------------------

Comments: