



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130305, Building Permit - Commercial  
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Commercial</b>	John Borns	Partial	Monday, June 10, 2013

Partial Correction  
1 MISC

**OK TO POUR WHEN READY ELEVATOR PIT WALLS**

**Comments:**