



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130503, Building Permit - Commercial  
Address: 232 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Wednesday, June 12, 2013

Partial Correction  
1 MISC

**OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ BOTH RESTROOM AFTER RESTROOM EXHAUST FAN HOSES ARE SECURED WITH APPROVED BANDS OR APPROVED TAPE + ISOLATE WATER PIPE FROM STEEL FRAMING AT ONE LOCATION.**

**Comments:**