

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX: 816-969-1201

Temporary Certificate of Occupancy

Permit #: Address: Inspected On: Inspected By: Expiration Date: PRCOM20121257 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086 Thursday, June 13, 2013 John Borns 7/25/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, June 13, 2013

Corrective Action Required:

2 MISC

ONLY SPACE 1F151A REMAINS TO BE APPROVED WHEN READY FOR FINAL INSPECTION. MED GAS EXHAUST IS REQUIRED IN THIS SPACE FOR INTENDED USE & OCCUPANCY.

Comments: DUE TO PROJECTED PROCUREMENT AND INSTALLATION TIME FOR EXHAUST EQUIPMENT ADAM OF TURNER CONSTRUCTION REQUESTED EXTENSION OF TCO.