



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRDEM20130355, Demolition

Address: 622 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081622 NW WILLOW DR,
Unit:C, LEES SUMMIT, MO 64081622 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Demo	John Borns	Failed	Friday, June 14, 2013

Corrective Action Required
1 MISC

SUBMISSION OF DEMOLITION DISPOSTION REPORT REQUIRED
(FORMS PROVIDED EARLIER).

Corrective Action Required
2 MISC

EROSION CONTROL REQUIRED AT DOWN-SLOPING
BOUNDARIES TO PREVENT SILT FROM WASHING TO STORM
INLETS.

Comments: