



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122619, Building Permit - Commercial
Address: 1744 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Passed	Monday, June 17, 2013
Above Ceiling Inspection	John Borns	Partial	Monday, June 17, 2013

Comments: OK TO COVER WHEN READY REMAINDER OF CEILING AREA AT FR1; FR2; HC FR; AND SALES NE AFTER MC ELECTRICAL CABLE IS SECURED WITHING 12" OF ENTRY TO J-BOX AT LOCATION POINTED-OUT.