



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130766, Building Permit - Commercial
Address: 1820 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, June 19, 2013

Partial Correction
1 MISC

NO ISSUES FOUND ON CONSTRUCTION OF LIGHT-GAUGE STEEL SOFFIT. HOWEVER, SUBSEQUENT ABOVE-GRID INSPECTION WILL BE REQUIRED BEFORE FINAL INSPECTION. ADVISE ELECTRICAL CONTRACTOR ALL ABOVE-CEILING WIRING AND DEVICES MUST BE CONFORMING AT THAT TIME.

Comments: