



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130791, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Wednesday, June 19, 2013

Partial Correction
1 MISC

OK TO POUR WHEN READY AFTER RE-BAR IS \geq 3" CLEAR OF
BOTTOMS & BANKS FOLLOWING SEGMENTS OF FOOTING FOR
RETAINING WALL: 0+00 TO 0+75; 0+75 TO 1+75; 1+ 75 TO 3+24

Comments: