

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20113275	Date:	June 21, 2013
Project Title:	HEARTLAND DENTAL CARE	Applicant:	
Location:			
691 NW BLUE PKWY, LEES SUMMIT, MO 64086		KCFS	
Type of Work:		901 E. Loula	
Occupancy Group:	B	Olathe, KS 66061	
Description:	TENANT FINSH FOR A		
DENTAL OFFICE IN PREVIOUSLY UNOCCUPIED		GRUNLOH BUILDING INC	
SPACE		901 NORTH SECOND ST	
Construction Type:	Type IIB (Unprotected)	EFFINGHAM, IL 62401	
Map Page:	195A		
		Primary: (217) 342-2221	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Plans received October 12, 2011.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule a test. Testing shall be done before the regular business hours of the neighboring tenants.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.