

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLAN REVIEW CONDITIONS

December 15, 2011

SAINT LUKES EAST HOSPITAL  
100 NW SAINT LUKES BOULEVARD  
LEES SUMMIT, MO 64064  
ACI BOLAND  
11229 NALL, SUITE 140  
LEAWOOD, KS 66211

Permit No: PRCOM20112915  
Project Title: SAINT LUKE'S  
Project Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086  
Parcel Number: 52400043900000000  
Location: SAINT LUKE'S HOSPITAL OF LEE'S SUMMIT LOT 1---LOT 1 (EX PT IN RD)  
Type of Work: ADDITION COMMERCIAL  
Occupancy Group: INSTITUTIONAL, INCAPACITATED  
Description: SAINT LUKE'S EAST ER ADDITION #2

*The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.*

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Approved**

1. This project requires a third party review of the electrical system. A permit can not be issued until that review has been completed and required corrections have been made.

Action required - Revised electrical sheets shall be provided based on the electrical comments provided.

3. 2006 IPC Section 801.2 - Protection. All devices, appurtenances, appliances and apparatus intended to serve some special function, such as sterilization, distillation, processing, cooling, or storage of ice or foods, and that discharge to the drainage system, shall be provided with protection against backflow, flooding, fouling, contamination and stoppage of the drain.

Action required - This comment is in regards to the ice machine in the clean room. Compliance will be verified on inspection.

### **Fire Plan Review**

**Reviewed By: Jim Eden**

**Approved**

1. No comments on resubmittal dated 11/3/11.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***