

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLAN REVIEW CONDITIONS

May 12, 2011

JAMS LEES BUSTER LLC  
605 W 47TH ST STE 200  
KANSAS CITY, MO 64112

Permit No: PRCOM20111185  
Project Title: GAMESTOP  
Project Address: 1041 NE SAM WALTON LN, Unit:A, LEES SUMMIT, MO 64086  
Parcel Number: 52840021700000000  
Location: RITTER PLAZA LOT 2 ( EX PT IN ROW)  
Type of Work: Change of Tenant  
Occupancy Group: Mercantile  
Description: CHANGE OF TENANT FROM BLOCKBUSTER TO GAME SALES

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Fire Plan Review**

**Reviewed By: Jim Eden**

**Rejected**

1. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

How is the new unit going to be addressed? Adjust the addressing on the existing doors as needed.

2. 1006.3 Illumination emergency power.

The power supply for means of egress illumination shall normally be provided by the premises' electrical supply.

In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas:

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
2. Corridors, exit enclosures and exit passageways in buildings required to have two or more exits.

3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.
  4. Interior exit discharge elements, as permitted in Section 1024.1, in buildings required to have two or more exits.
  5. Exterior landings, as required by Section 1008.1.5, for exit discharge doorways in buildings required to have two or more exits.
- The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702 of the International Building Code.

Provide exterior emergency lighting over the new doors.

3. Provide remote LED/Audible/reset panels for the duct detectors.

**Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Pending**

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***