

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

| | | | |
|--------------------|---------------------------------------|------------|----------------------|
| Permit No: | PRCOM20112705 | Date: | May 18, 2012 |
| Project Title: | HY-VEE GAS #2 | Applicant: | |
| Location: | | | |
| | 1201 SW 3RD ST, LEES SUMMIT, MO 64081 | | A+ Communications |
| Type of Work: | | | 5609 NE 22nd Street |
| Occupancy Group: | M | | Des Moines, IA 50313 |
| Description: | NEW CONVIENCE STORE | Primary: | <NO PRIMARY PHONE> |
| | AND GAS ISLANDS | | |
| Construction Type: | Type VB (Unprotected) | | |
| Map Page: | 195E | | |

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Rejected

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received on May 1, 2012.

4. Duct detection shall be supervisory only and shall not activate interior horn/strobes.

Verified at inspection.

6. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Revised plans received on May 18, 2012.

2. Duct detection shall be supervisory only and shall not activate interior horn/strobes.

Verified at inspection.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.