

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100137	Date:	June 30, 2011
Project Title:	LA FUENTE	Applicant:	PROGRESSIVE ELECTRONICS
Location:	1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086		6102 ARLINGTON RAYTOWN, MO. 64133
Type of Work:	NEW	Primary:	(816)765-5750
Occupancy Group:	A-2		
Description:	RESTAURANT		
Construction Type:	Type VB (Unprotected)		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Rejected

1. Fire Dept- need to show an exterior horn strobe on the south side by the FDC. This is to activate only for sprinkler water flow
2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action Required: Call 969-1300 to schedule alarm and hood test prior to final

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Fire Dept- need to show an exterior horn strobe on the south side by the FDC. This is to activate only for sprinkler water flow

ADDRESSED IN RESUB, RELEASED FOR CONSTRUCTION

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action Required: Call 969-1300 to schedule alarm and hood test prior to final

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.