

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20110083	Date:	April 19, 2012
Project Title:	CVS Pharmacy	Applicant:	
Location:			
621 SW 3RD ST, LEES SUMMIT, MO 64063			<NO CONTACT NAME AVAILABLE>
Type of Work:			<NO CONTACT INFORMATION AVAILABLE>
Occupancy Group:	M		
Description:	CVS Pharmacy Building		
Construction Type:	Type VB (Unprotected)		
Map Page:	195F		
		ALLIANCE FIRE PROTECTION LLC	
		130 WEST 9TH AVE	
		NORTH KANSAS CITY, 64116	
		Primary:	<NO PRIMARY PHONE>

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received 4/14/2012.

2. Confirm coverage of the VRC from the mezzanine. Verified at inspection.

3. The FDC shall be a 4inch Storz type connection.

4. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow testing.

5. Systems shall be designed to the 2006 IBC and 2002 NFPA 13.

For information only.

6. The Flow Test data for the site was taken from over a 1/2 mile away. Confirm flow data for the site and make changes as needed. Provide documentation of second test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.