

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20122702	Date:	April 15, 2013
Project Title:	STANLEY EVENT CENTER	Applicant:	
Location:	308 SE DOUGLAS ST, LEES SUMMIT, MO 64063		FIRE AND SECURITY SOLUTIONS GROUP INC 6025 MARTWAY, SUITE 104 MISSION, KS 66202
Type of Work:			
Occupancy Group:	A-2		
Description:	STANLEY EVENT CENTER COMMERCIAL BUILDING	Primary:	(913) 789-7160
Construction Type:	Type IIB (Unprotected)		
Map Page:	195G		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Alarm Plan Review**

**Reviewed By: Brian Austerman**

**Released for Construction**

1. Duct detection not shown on plans, to be added per our discussion on 4/15/2013
2. Add manual pull station to 3rd floor stairwell, per our discussion

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**