

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20122713	Date:	February 22, 2013
Project Title:	LIFE TRANSFORMATIONS	Applicant:	
FITNESS CENTER			
Location:		Straight Access & Security LLC	
3680 NE AKIN DR, Unit:130, LEES SUMMIT, MO		7109 Noland	
64064		Shawnee, KS 66216	
Type of Work:		Primary: <NO PRIMARY PHONE>	
Occupancy Group:	A-4		
Description:	TENANT FINISH FOR FITNESS		
CENTER			
Construction Type:	Type IIB (Unprotected)		
Map Page:	175H		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Address on plan shows 3680 NE Ralph Powell Rd, however the address on the permit is 3680 NE Akin, for information only
2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816)0 969-1300 to schedule alarm testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.