

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

September 23, 2011

FORD & ASSOCIATES
1500 W 1ST AVE
COLUMBUS, OH 43212

Permit No: PRCOM20114324
Project Title: TIME WARNER CABLE
Project Address: 188 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Parcel Number: 62140031600000000
Location: SUMMIT SHOPPING CENTER LOT 1
Type of Work: Change of Tenant
Occupancy Group: MERCANTILE
Description: TENANT FINISH FOR RETAIL FACILITY

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Approved

3. 2006 IFC 703.1- Maintenance. The required fire-resistance rating of fire-resistance-rated construction (including walls, firestops, shaft enclosures, partitions, smoke barriers, floors, fire-resistive coatings and sprayed fire-resistant materials applied to structural members and fire-resistant joint systems) shall be maintained. Such elements shall be properly repaired, restored or replaced when damaged, altered, breached or penetrated. Openings made therein for the passage of pipes, electrical conduit, wires, ducts, air transfer openings and holes made for any reason shall be protected with approved methods capable of resisting the passage of smoke and fire. Openings through fire-resistance-rated assemblies shall be protected by self- or automatic-closing doors of approved construction meeting the fire protection requirements for the assembly.

Verified at inspection.

4. All plans submitted for review on or after July 9, 2007 shall be designed to the requirements of the 2006 International Building Code, 2006 International Mechanical Code, 2006 International Plumbing Code, 2006 International Fuel Gas Code, 2006 International Fire Code, 2005 National Electric Code and the ANSI A117.1-2003 as amended and adopted by the City of Lees Summit.

For information only.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.