

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100137	Date:	June 08, 2011
Project Title:	LA FUENTE	Applicant:	ALPHA FIRE PROTECTION
Location:	1255 NE DOUGLAS ST. LEES SUMMIT, MO 64086	P.O. Box 50	
Type of Work:	Sprinkler	Independence, MO 64051	
Occupancy Group:	A-2		
Description:	RESTAURANT		
Construction Type:	Type VB (Unprotected)		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Revised plans recieved June 1,2011.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816)969-1300 to schedule hydrostatic and flow tests.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.