

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20114350	Date: June 26, 2012
Project Title:	CHICK-FIL-A SUMMIT FAIR	Applicant:
Location:	690 NW BLUE PKWY. LEES SUMMIT, MO 64086	ALLIANCE FIRE PROTECTION LLC, SUITE 101 130 WEST 9TH AVE NORTH KANSAS CITY, 64116 (913) 888-0647
Type of Work:	Antifreeze Loop	
Occupancy Group:	A-2	
Description:	RESTAURANT	
Construction Type:	Type VB (Unprotected)	
Map Page:	195A	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received for the anti-freeze line addition on June 21, 2012.

2. The pressure relief valve shall be listed for fire protection system use (Watts FP53L or equivalent). Verified at inspection.

3. The valves to the anti-freeze system shall be electronically supervised. Verified at inspection.