

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

June 10, 2013

MEYER BROTHERS BUILDING CO
800 E 101ST TER, SUITE 120
KANSAS CITY, MO 64131

Permit No: PRCOM20131124
Project Title: INSTANT AUTO
Project Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064
Parcel Number: 52500012100000000
Location: SUMMIT PLAZA---LOT 3 (EX PT IN ROW)
Type of Work: PARTIAL COMMERCIAL
Occupancy Group: BUSINESS
Description: FOUNDATION

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

1. The project cost, which is used to establish the permit fee, has not been provided.

Action required - Provide the cost of the foundation work.

2. 2006 IBC 1704.1.1 - Statement of special inspections. The permit applicant shall submit a statement of special inspections prepared by the registered design professional in responsible charge in accordance with 106.1 as a condition for permit issuance. This statement shall be in accordance with Section 1705.

Exceptions: 1. A statement of special inspections is not required for structures designed and constructed in accordance with the conventional construction provisions of Section 2308. 2. The statement of special inspections is permitted to be prepared by a qualified person approved by the building official for construction not designed by a registered design professional.

Action required - Provide a statement of special inspections.

3. 2006 IBC 1704.1.2 - Report Requirement. Special inspectors shall keep records of inspections. The special inspector shall furnish inspection reports to the building official, and to the registered design professional in responsible charge. Reports shall indicate that work inspected was done in conformance to approved construction documents. Discrepancies shall be brought to the immediate attention of the contractor for correction. If the discrepancies are not corrected, the discrepancies shall be brought to the attention of the building official and to the registered design professional in responsible charge prior to the

completion of that phase of the work. A final report documenting required special inspections and correction of any discrepancies noted in the inspections shall be submitted at a point in time agreed upon by the permit applicant and the building official prior to the start of work.

Action required - This comment is for information purposes.

Fire Plan Review

Reviewed By: Brian Austerman

Rejected

1. Provide civil plans, including fire department access roads, fire hydrants and the FDC on the building. The FDC is to be located no more than 100' from a fire hydrant
2. Provide complete MEP's showing emergency lighting, exiting and details on HVAC units
3. Provide information on waste oil furnace and tank in order to evaluate for the need of a hazardous materials permit for storage and use
4. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide sprinkler plans for approval

5. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide alarm plans for approval

6. 2006 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

Call (816) 969-1300 to obtain a knox box application

7. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide one 2A10B:C extinguisher for every 3,000 sq/ft, verified at inspection

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.