



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Monday, June 24, 2013

Partial Correction

1 MISC

OK TO COVER WHEN READY FOLLOWING PORTIONS OF UNDER-SLAB PVC **SANITARY DRAIN, WASTE, & VENT PIPING**: H.6/7.3 TO H.6/7.1 TO F.7/7.1 TO F.7/7.9;

NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Partial Correction

2 MISC

OK TO COVER WHEN READY FOLLOWING PORTIONS OF UNDER-SLAB **STORM DRAIN PIPING**: J.15/7.4 TO J.15/7.1 TO F.7/7.1 TO F.7/7.9;

NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Comments: