

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

January 03, 2012

ACI BOLAND
11229 NALL, SUITE 140
LEAWOOD, KS 66211

Permit No: PRCOM20116335
Project Title: SAINT LUKES EAST IT / ADMITTING REMODEL
Project Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Parcel Number: 52400043900000000
Location: SAINT LUKE'S HOSPITAL OF LEE'S SUMMIT LOT 1---LOT 1 (EX PT IN RD)
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: INSTITUTIONAL, INCAPACITATED
Description: REMODEL SHELL SPACE ON THIRD FLOOR OF HOSPITAL FOR IT & MARKETING OFFICES. IT WILL MOVE OUT OF ADMITTING AREA ON 1ST FLOOR AND ADMITTING AREA WILL BE REMODELED TO ADD 2 OFFICES. IT SPACE WILL BE USED FOR STAFF OFFICES AND TO BUILDING COMPUTER WORKSTATIONS.

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Approved

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for sprinkler alteration.

2. 2006 IFC 703.1- Maintenance. The required fire-resistance rating of fire-resistance-rated construction (including walls, firestops, shaft enclosures, partitions, smoke barriers, floors, fire-resistive coatings and sprayed fire-resistant materials applied to structural members and fire-resistant joint systems) shall be maintained. Such elements shall be properly repaired, restored or replaced when damaged, altered, breached or penetrated. Openings made therein for the passage of pipes, electrical conduit, wires, ducts, air transfer openings and holes made for any reason shall be protected with approved methods capable of resisting the passage of smoke and fire. Openings through fire-resistance-rated assemblies shall be protected by self- or automatic-closing doors of approved construction meeting the fire protection requirements for the assembly.

Verified at inspection.

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.