LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

February 14, 2012

J E DUNN CONSTRUCTION
1001 LOCUST
KANSAS CITY, MO 64106
P1 GROUP INC
16210 WEST 108TH ST
LENEXA, KS 66219
SHAW ELECTRIC COMPANY
3600 FULLER AVE
KANSAS CITY, MO 64129
P1 GROUP INC
16210 WEST 108TH ST
LENEXA, KS 66219
SAINT LUKES EAST HOSPITAL
100 NW SAINT LUKES BOULEVARD
LEES SUMMIT, MO 64064

Permit No: PRCOM20120186

Project Title: SAINT LUKES EAST CARDIAC REHAB

Project Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

Parcel Number: 52400043900000000

Location: SAINT LUKE'S HOSPITAL OF LEE'S SUMMIT LOT 1---LOT 1 (EX PT IN RD)

Type of Work: ALTERATION COMMERCIAL

Occupancy Group: BUSINESS

Description: CARDIAC REHAB REMODEL

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review Reviewed By: Jim Eden Approved

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule a test of the relocated alarm appliances.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.