

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLAN REVIEW CONDITIONS

September 07, 2012

HENDERSON ENGINEERS  
8325 LENEXA DR SUITE 400  
LENEXA KS, KS 66214

Permit No: PRCOM20122020  
Project Title: LSHS ROBOTIC  
Project Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063  
Parcel Number: 61510026300000000  
Location: MUCKEY ADD PT OF LOT 1 & PT N 1/2 SEC 08-47-31 DAF: BEG AT SW COR SD LOT 1 TH N 220' TH E 88.5' TH N 65' MOL TH E 88.5' TH S 290' TO SE COR SD LOT 1 TH E 1110' MOL TO WLY ROW LI M-291 HWY TH SLY ALG SD ROW 1070' MOL TH W 435' MOL TH S 510' TO NLY ROW LI BLUE PARKWAY TH W ALG SD ROW 850' MOL TH N 812' MOL TH W 135' MOL TH N 678' MOL TH E 135.77' TH N 95' MOL TO POB  
Type of Work: REPAIR/REPLACE/UPGRADE  
Occupancy Group:  
Description: MODIFY/ADD TO ELECTRICAL

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved with Conditions**

#### **1. 605.5 Extension cords.**

Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances.

For information only

#### **2. 605.5.1 Power supply.**

Extension cords shall be plugged directly into an approved receptacle, power tap or multiplug adapter and, except for approved multiplug extension cords, shall serve only one portable appliance.

For information only

#### **3. 605.4.2 Power supply.**

Relocatable power taps shall be directly connected to a permanently installed receptacle.

For information only

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***