

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

June 04, 2013

CITY OF LEES SUMMIT
PO BOX 1600
LEES SUMMIT, MO 64063

Permit No: PRCOM20131037
Project Title: GREAT BEGINNINGS EARLY CHILDHOOD CENTER
Project Address: 905 NE BLUESTEM DR, LEES SUMMIT, MO 64086
Parcel Number: 53800010401000000
Location: SEC-35 TWP-48 RNG-31 W 1/2 NE 1/4 & ALL NW 1/4 & W 1/2 SE 1/4 & SW 1/4 (EX PT DAF: BEG SW COR SD SW 1/4 TH E 990' TH N 660' TH W 990' TH S 660' TO POB (EX PT IN RD)
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: EDUCATIONAL
Description: GREAT BEGINNINGS EARLY CHILDHOOD CENTER INTERIOR ALTERATIONS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

Fire Plan Review

Reviewed By: Brian Austerman

Approved with Conditions

1. 1008.1.3.4 Access-controlled egress doors.

The entrance doors in a means of egress in buildings with an occupancy in Group A, B, E, M, R-1 or R-2 and entrance doors to tenant spaces in occupancies in Groups A, B, E, M, R-1 and R-2 are permitted to be equipped with an approved entrance and egress access control system which shall be installed in accordance with all of the following criteria:

1. A sensor shall be provided on the egress side arranged to detect an occupant approaching the doors. The doors shall be arranged to unlock by a signal from or loss of power to the sensor.
2. Loss of power to that part of the access control system which locks the doors shall automatically unlock the doors.
3. The doors shall be arranged to unlock from a manual unlocking device located 40 inches to 48 inches (1016 mm to 1219 mm) vertically above the floor and within 5 feet (1524 mm) of the secured doors. Ready access shall be provided to the manual unlocking device and the device shall be clearly identified by a sign that reads "PUSH TO EXIT." When operated, the manual unlocking device shall result in direct interruption of power to the lock—independent of the access control system electronics—and the doors shall remain unlocked for a minimum of 30 seconds.

4. Activation of the building fire alarm system, if provided, shall automatically unlock the doors, and the doors shall remain unlocked until the fire alarm system has been reset.
5. Activation of the building automatic sprinkler or fire detection system, if provided, shall automatically unlock the doors. The doors shall remain unlocked until the fire alarm system has been reset.
6. Entrance doors in buildings with an occupancy in Group A, B, E or M shall not be secured from the egress side during periods that the building is open to the general public.

Doors with electric locks or other access controlled features shall not impede access upon activation of the fire alarm. For information only

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.