LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS 207 SE DOUGLAS STREET LEE'S SUMMIT, MISSOURI 64063-2372 (816) 969-1309 FAX (816) 969-1313 TDD (816) 969-7467

PLAN REVIEW CONDITIONS

April 01, 2013

HY-VEE WEITZ CONSTRUCTION 5605 NE 22ND ST DES MOINES, IA 50313

Permit No: PRCOM20130506

Project Title: HY-VEE

Project Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

Parcel Number: 62610023400000000 Location: WAL-MART TRACT A

Type of Work: ALTERATION COMMERCIAL

Occupancy Group:

Description: BUILDING ALTERATIONS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Brian Austerman

Rejected

1. 2006 IFC 609.2- Where required. A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease vapors.

Provide information on the charbroiler, will there be grease laden vapors and if so wubmit plans for a type 1 (protected) hood

2. Provide detail on fuel types to be used for the charbroiler, gas and or solid fuel

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.