

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLAN REVIEW CONDITIONS

April 23, 2013

CBL LEES SUMMIT EAST LLC  
2030 HAMILTON PLACE BLVD STE 500  
CHATTANOOGA, TN 64086  
NOEL WALLCOVERINGS  
8620 E 83RD  
RAYTOWN, MO 64138  
CALABRESE GOOD ARCHITECTS  
134 WEST MAIN STREET  
LEOLA, PA 17540

Permit No: PRCOM20130346  
Project Title: FRANCESCA'S: SUMMIT FAIR  
Project Address: 860 NW BLUE PKWY, Unit:L, LEES SUMMIT, MO 64086  
Parcel Number: 51700033300000000  
Location: SUMMIT FAIR LOTS 22A & 24A---LOT 22A  
Type of Work: NEW TENANT FINISH  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH

*The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.*

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Approved with Conditions**

2. 2006 IPC 403.4 - Required public toilet facilities. Customers, patrons and visitors shall be provided with public toilet facilities in structures and tenant spaces intended for public utilization. The accessible route to public facilities shall not pass through kitchens, storage rooms, closets or similar spaces. Employees shall be provided with toilet facilities in all occupancies. Employee toilet facilities shall be either separate or combined employee and public toilet facilities.

Action required - This comment is for information purposes and will be verified on inspection.

4. ICC/ANSI A117.1 2003 606.2 - Clear floor space. A clear floor space complying with Section 305.3, positioned for forward approach, shall be provided. Knee and toe clearance complying with Section 306 shall be provided. The dip of the overflow shall not be considered in determining knee and toe clearance. (See code for possible exceptions.)

Action required - The installation of the instantaneous water heater shall not conflict with this requirement. To be verified on inspection.

**Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved**

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide sprinkler plans for approval if modifying the existing system

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide alarm plans for approval if modifying the existing system

3. 1006.3 Illumination emergency power.

The power supply for means of egress illumination shall normally be provided by the premises' electrical supply.

In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas:

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
2. Corridors, exit enclosures and exit passageways in buildings required to have two or more exits.
3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.
4. Interior exit discharge elements, as permitted in Section 1024.1, in buildings required to have two or more exits.
5. Exterior landings, as required by Section 1008.1.5, for exit discharge doorways in buildings required to have two or more exits.

The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702 of the International Building Code.

Provide exterior emergency lighting if not already existing.

RESOLVED IN RESUBMITTAL

4. The sprinkler control valve in the corridor shall be marked with the correct suite number, verified at inspection

**Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved**

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***