

June 10, 2013

Attn: Mike Wisenborn
Department of Codes Administration
City of Lee's Summit
220 SE Green St.
Lee's Summit, MO 64063

RECEIVED

JUN 11 2013

RE: Golden Paws Grooming
848 SW Blue Parkway

**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

Mr. Weisenborn,

This letter shall modify the original submitted plan set for a remodel of the above referenced location. Please attach this letter to the plan set.

Item 1: All references to the ADA compliant restroom shall be considered removed. The original facility was constructed in accordance to appropriate standards but does not meet the ANSI standards currently used by the City of Lee's Summit.


Item 2: All windows within 24 inches of a finished vertical door opening shall comply with Chapter 24 of the International Building Code.

If there are any questions regarding this analysis, please contact our Offices.

Very Truly Yours,

R.E.O. ENGINEERING, P.C.

By: Aaron D. Obermiller, Vice-President
Aaron D. Obermiller, P.E.



*Approved 6-12-13
Mike Wisenborn*