

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

February 03, 2012

CITY OF LEES SUMMIT
PO BOX 1600
LEES SUMMIT, MO 64063--7600

Permit No: PRCOM20120116
Project Title: CITY HALL RENOVATIONS
Project Address: 220 SE GREEN ST, LEES SUMMIT, MO 64063
Parcel Number: 61230162300000000
Location: LEES SUMMIT CITY HALL---LOT 1
Type of Work: REPAIR/REPLACE/UPGRADE
Occupancy Group: BUSINESS
Description: REPLACE COMPUTER ROOM HVAC SYSTEMS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Approved

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for the clean agent systems for review and approval.

2. Acknowledging the marked out words on the submitted drawings. It is understood that NO automatic sprinkler systems or components will be removed and all areas will be protected in accordance with NFPA 13 and the IFC.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule room fan tests and discharge tests.

4. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing system shall have documentation of a current annual inspection. Verified at inspection.

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

1. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Expert from Sec. 7-130, Lees Summit Code of Ordinances.

Action required - Provide the names of these contractors prior to permit approval.

2. The floor/ceiling assembly above rooms 1.111 and 1.112 is a fire-resistant assembly. Any penetrations of this assembly shall be sealed in an approved manner.

Action required - This will be verified on inspection.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.