

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

May 31, 2012

GUY GRONBERG ARCHITECTS, PC
113 SE 3RD ST
LEES SUMMIT, MO 64063--2719

Permit No: PRCOM20121142
Project Title: EAGLE CREEK CHURCH
Project Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081
Parcel Number: 61800320800000000
Location: SOUTH PORT BUSINESS PARK LOT 12-A LOT 12-A
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: ASSEMBLY FOR WORSHIP, RECREATION OR AMUSEMENT
Description: REMODEL TO ENLARGE WORSHIP HALL

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Rejected

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for sprinkler and alarm system alterations.

3. 2006 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

4. Door hardware from the building and assembly areas shall be panic hardware. Confirmed at inspection.

5. Provide electrical drawings showing exit and emergency lighting.

6. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Show the locations of the fire extinguishers to be provided.

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.