

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20121257	Date:	July 09, 2012
Project Title:	SAINT LUKES EAST 4TH FLOOR SURGICAL ICU	Applicant:	
Location:	110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086		CENTURY FIRE SPRINKLERS INC 1233 SOUTHWEST BOULEVARD KANSAS CITY, KS 66103--1999
Type of Work:			
Occupancy Group:	I-2		<NO CONTACT NAME AVAILABLE>
Description:	TENANT FINISH FOR INTENSIVE CARE UNIT		<NO CONTACT INFORMATION AVAILABLE>
Construction Type:	Type IA		
Map Page:	175X	Primary:	(913) 321-9208

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Rejected

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received June 19, 2012.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule testing.

3. Provide a Class 1, 2 1/2 inch hose valve and cabinet in the corridor outside of ICU #10.

4. Extend a Class 1, 2 1/2 inch hose valve from the north stair (A410) into the corridor (4F021) from the hospital stair riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.