

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20122702	Date:	March 26, 2013
Project Title:	STANLEY EVENT CENTER	Applicant:	
Location:	308 SE DOUGLAS ST, LEES SUMMIT, MO 64063		ALLIANCE FIRE PROTECTION LLC 130 WEST 9TH AVE NORTH KANSAS CITY, 64116
Type of Work:			
Occupancy Group:	A-2		
Description:	STANLEY EVENT CENTER COMMERCIAL BUILDING	Primary:	(913) 888-0647
Construction Type:	Type IIB (Unprotected)		
Map Page:	195G		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call 969-1300 to schedule hydrostatic test

2. Call 969-1300 to schedule flow test in conjunction with the alarm test prior to final

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.