

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20130263	Date:	April 15, 2013
Project Title:	SHEAR MADNESS	Applicant:	
Location:	950 NW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64086		BAMFORD FIRE SPRINKLER CO INC 5134 MERRIAM DRIVE SHAWNEE MISSION, KS 66203--2158
Type of Work:			
Occupancy Group:	B		
Description:	SHEAR MADNESS TENANT FINISH	Primary:	(913) 432-6688
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Control valve in corridor needs to be marked with the suite number

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.