

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20130346	Date:	May 31, 2013
Project Title:	FRANCESCA'S: SUMMIT FAIR	Applicant:	ABSOLUTE FIRE INC
Location:	860 NW BLUE PKWY, Unit:L, LEES SUMMIT, MO 64086		5899 RAYTOWN ROAD RAYTOWN, MO 64133--3384
Type of Work:		Primary:	(816) 737-9991
Occupancy Group:	M		
Description:	TENANT FINISH		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review                      Reviewed By: Brian Austerman                      Rejected**

1. Provide plans showing the actual scope of work, including what is existing, what has been moved and what was added. Also show where the flow valve, supply line and branch lines are located.

**Sprinkler Plan Review                      Reviewed By: Brian Austerman                      Released for Construction**

1. Provide plans showing the actual scope of work, including what is existing, what has been moved and what was added. Also show where the flow valve, supply line and branch lines are located.

2. Supplemental information received on 5/30/2013. Released for construction 5/31/2013

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**