

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No: PRCOM20130446 Date: June 19, 2013  
Project Title: SAINT LUKES EAST - Applicant: JAYHAWK FIRE SPRINKLERS  
FIFTH FLOOR MEDICAL 10629 SUMMIT STREET  
ONCOLOGY LENEXA, KS 66215--2051  
Location: 110 NE SAINT LUKES BLVD,  
Unit:520, LEES SUMMIT, MO 64086 Primary: (913) 422-3770  
Type of Work:  
Occupancy Group: B  
Description: MEDICAL  
ONCOLOGYBUILDING "F" FIFTH FLOOR  
Construction Type: Type IA  
Map Page: 175X

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Sprinkler Plan Review**

**Reviewed By: Brian Austerman**

**Released for Construction**

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic testing

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**