

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

| | | | |
|---|------------------------|------------------------------------|-----------------|
| Permit No: | PRCOM20113089 | Date: | August 11, 2011 |
| Project Title: | CHRISTOPHER & BANKS | Applicant: | |
| Location: | | | |
| 930 NW BLUE PKWY, Unit:V, LEES SUMMIT, MO | | National Fire Suppression | |
| 64086 | | 501 Sunshine Road | |
| Type of Work: | | Kansas City, KS 66115 | |
| Occupancy Group: | M | | |
| Description: | NEW TENANT FINISH IN | <NO CONTACT NAME AVAILABLE> | |
| PREVIOUSLY UNOCCUPIED SPACE | | <NO CONTACT INFORMATION AVAILABLE> | |
| Construction Type: | Type IIB (Unprotected) | | |
| Map Page: | 195A | | |
| | | Primary: (913) 321-9208 | |

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received August 9, 2011.

2. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Action required: The existing sprinkler system shall have documentation of a current annual inspection.
Verified at inspection.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required: Call (816) 969-1300 to schedule hydrostatic and flow tests.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.