

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20116335	Date:	January 03, 2012
Project Title:	SAINT LUKES EAST IT /	Applicant:	
	ADMITTING REMODEL		
Location:	SHAW ELECTRIC COMPANY		
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO	3600 FULLER AVE		
64086	KANSAS CITY, MO 64129		
Type of Work:			
Occupancy Group:	I-2	J E DUNN CONSTRUCTION	
Description:	REMODEL SHELL SPACE ON	1001 LOCUST	
THIRD FLOOR OF HOSPITAL FOR IT &		KANSAS CITY, MO 64106	
MARKETING OFFICES. IT WILL MOVE OUT OF			
ADMITTING AREA ON 1ST FLOOR AND		Primary: (816) 474-8600	
ADMITTING AREA WILL BE REMODELED TO			
ADD 2 OFFICES. IT SPACE WILL BE USED FOR			
STAFF OFFICES AND TO BUILDING COMPUTER			
WORKSTATIONS.			
Construction Type:	Type IA		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Hold open devices and notification appliances to be tested at occupancy inspection.

2. Replace the visual appliance in the Admitting area.

Verified at inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.