

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20121047	Date:	September 24, 2012
Project Title:	PEPPERJAX GRILL	Applicant:	
Location:	1720 NW CHIPMAN RD, LEES SUMMIT, MO 64081		
Type of Work:		TED SYSTEMS LLC	
Occupancy Group:	A-2	12314 WEST 62ND TERRACE	
Description:	PEPPERJAX GRILL TENANT	SHAWNEE, KS 66216--1861	
FINISH, SPACE WAS PREVIOUSLY A BEAUTY		Primary: (913) 677-5771	
SUPPLY STORE			
Construction Type:	Type VB (Unprotected)		
Map Page:	194D		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Alarm Plan Review**

**Reviewed By: Brian Austerman**

**Released for Construction**

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action Required: Call (816) 969-1300 to schedule hood and alarm system testing prior to final

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**