

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20121405	Date:	September 05, 2012
Project Title:	ASPEN ATHLETIC CLUB	Applicant:	
Location:	178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081		<NO CONTACT NAME AVAILABLE> <NO CONTACT INFORMATION AVAILABLE>
Type of Work:			
Occupancy Group:	A-4		
Description:	COMPLETE INTERIOR BUILDOUT	DARLAND CONSTRUCTION	
Construction Type:	Type IIB (Unprotected)	4115 SOUTH 133RD ST	
Map Page:	195E	OMAHA, NE 68137	
		Primary: (402) 827-8200	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. OUTSIDE HORN STROBE TO ACTIVATE ON WATERFLOW ALARM ONLY, VERIFIED AT ALARM TESTING
2. DUCT DETECTORS SHALL TRANSMIT A SUPERVISORY SIGNAL TO THE PANEL AND SHUT DOWN THE UNIT, VERIFIED AT ALARM TESTING
3. CALL 816-969-1300 TO SCHEDULE ALARM TESTING PRIOR TO THE FINAL

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.