

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20130503	Date:	June 25, 2013
Project Title:	SEARS	Applicant:	Electronic Contracting Company
Location:	232 NW OLDDHAM PKWY, LEES SUMMIT, MO 64081		6020 Parretta Drive Kansas City, MO 64120
Type of Work:		Primary:	816-561-6800
Occupancy Group:	M		
Description:	TENANT FINISH		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195E		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing prior to final

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.