LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS 207 SE DOUGLAS STREET LEE'S SUMMIT, MISSOURI 64063-2372 (816) 969-1300 FAX (816) 969-1313 TDD (816) 969-7467

PLANS REVIEW CONDITIONS

Permit No: PRCOM20114943 Project Title: SAINT LUKES EAST - SURGICENTER ADDITION Location: 120 NE SAINT LUKES BLVD. LEES SUMMIT, MO 64086 Type of Work: Sprinkler Occupancy Group: I-2 Description: SURGICAL ADDITION 1st FLR.TENANT FINISH Construction Type: Type IA Map Page: 175X

Date: June 07, 2012 Applicant: JAYHAWK FIRE SPRINKLERS 10629 SUMMIT STREET LENEXA, KS 66215--2051 (913) 422-3770

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow testing.

2. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Revised first floor tenamnt finish plans received May 31, 2012.

3. Ensure that the FHC at the door is located inside of vestibule 135.

Verified at inspection.