

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

| | | | |
|--------------------|---|------------|------------------|
| Permit No: | PRCOM20116335 | Date: | January 26, 2012 |
| Project Title: | SAINT LUKES EAST IT / ADMITTING REMODEL | Applicant: | |
| Location: | JAYHAWK FIRE SPRINKLERS 10629 SUMMIT STREET 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086 | | |
| Type of Work: | | Primary: | (913) 422-3770 |
| Occupancy Group: | I-2 | | |
| Description: | REMODEL SHELL SPACE ON THIRD FLOOR OF HOSPITAL FOR IT & MARKETING OFFICES. IT WILL MOVE OUT OF ADMITTING AREA ON 1ST FLOOR AND ADMITTING AREA WILL BE REMODELED TO ADD 2 OFFICES. IT SPACE WILL BE USED FOR STAFF OFFICES AND TO BUILDING COMPUTER WORKSTATIONS. | | |
| Construction Type: | Type IA | | |
| Map Page: | 175X | | |

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. Alterations shall be designed and completed to the 2002 edition of NFPA 13.
2. Alterations will be inspected at occupancy inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.