

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20121481	Date:	September 07, 2012
Project Title:	SAINT LUKES SURGICAL SPECIALISTS	Applicant:	JAYHAWK FIRE SPRINKLERS
Location:	120 NE SAINT LUKES BLVD, Unit:220 LEES SUMMIT, MO 64086		10629 SUMMIT STREET LENEXA, KS 66215--2051 (913) 422-3770
Type of Work:	Sprinkler Alteration		
Occupancy Group:	B		
Description:	NEW TENANT FINISH FOR MEDICAL OFFICE		
Construction Type:	Type IA		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received Aug. 27, 2012.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

3. For information only -Attach the slugs from the snap-o-let installation to the pipe for inspection.