

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20121010	Date:	December 07, 2012
Project Title:	SAINT LUKES HOSPITAL 5TH FLOOR SHELL	Applicant:	
Location:	100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086	JAYHAWK FIRE SPRINKLERS 10629 SUMMIT STREET LENEXA, KS 66215--2051	
Type of Work:		Primary: (913) 422-3770	
Occupancy Group:	I-2		
Description:	5TH FLOOR SHELL Mike Weisenborn 09/20/2012 8:34 AM - THIS PERMIT ALSO INCLUDES THE FOLLOWING WORK IN BUILDING F, 110 NE SAINT LUKE'S BLVD. COMPLETION OF VESTIBULE 1F008. COMPLETION OF ENTRANCE 1F007B. COMPLETION OF SITE WORK NORTH OF BUILDING AS SHOWN ON SHEET C2.0 AND C3.0		
Construction Type:	Type IA		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call 816-969-1300 to schedule hydrostatic, flow and alarm tests

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.