

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20122128	Date:	October 05, 2012
Project Title:	ARNOLD HALL	Applicant:	
Location:	123 SE 3RD ST LEES SUMMIT, MO 64063		ADVANTAGE FIRE PROTECTION SYSTEMS 404 B NORTHWEST 11TH STREET BLUE SPRINGS, MO 64015--3638 (816) 224-3400
Type of Work:	Sprinkler alteration after demo.		
Occupancy Group:	Assembly		
Description:	ALTERATIONS TO EXISTING FIRE SPRINKLER SYSTEM		
Construction Type:			
Map Page:	195G		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

As built plans received Sept 17, 2012. Provide a NICET or PE stamp on the plans.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call to schedule a hydrostatic and flow test.

3. 907.4.4 Signs.

Where fire alarm systems are not monitored by a supervising station, an approved permanent sign shall be installed adjacent to each manual fire alarm box that reads: WHEN ALARM SOUNDS—CALL FIRE DEPARTMENT.

Verified at inspection.