LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1303
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No: PRCOM20122034

Project Title: LOFT

Location: 860 NW BLUE PKWY, Unit:T,

LEES SUMMIT, MO 64086

Type of Work:

Occupancy Group: M

Description: TENANT FINISH FOR

CLOTHING STORE

Construction Type: Type IIB (Unprotected)

Map Page: 195A

Date: March 11, 2013

Applicant:

ABSOLUTE FIRE INC 5899 RAYTOWN ROAD RAYTOWN, MO 64133--3384

Primary: (816) 737-9991

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Brian Austerman Released for Construction

1. Control Valve in corridor shall be marked with proper suite number. Verified at inspection.

Call 969-1300 to schedule flow and alarm testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.