

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100223	Date:	December 30, 2010
Project Title:	Smallcakes	Applicant:	
Project Address:	880 NW BLUE PKWY, Unit:G, LEES SUMMIT, MO 64086		Innovative Design and Renovation
Location:	SUMMIT FAIR LOTS 22A & 24A---LOT 22A		2 West 52nd St Kansas City, MO 64112
Type of Work:	New Tenant Finish		
Occupancy Group:	Mercantile		
Description:	Smallcakes Tenant finish		

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Approved

1. Fire Department- 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action required: Provide shop drawings for sprinkler system alteration.

Action required: The sprinkler system was altered for the white box finish and not the tenant finish. Adjust sprinkler coverage as needed for the addition of the center wall.,

3. Fire Department- 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action required: Provide interior alarm appliances. Provide shop drawings for alarm system installation/alteration.,

6. Fire Department- 2006 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

Action required: Calculate the occupant load as an A2 occupancy with (unconcentrated tables and chairs), and post the same. Verified at inspection.

Action required: The occupant load needs to be recalculated using IFC Table 1004.1.1.,

_____ Approved to issue per the listed conditions.

_____ Do not issue per the listed conditions.

_____ Approved to construct foundation only per the listed conditions.

_____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.