

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100272	Date:	December 14, 2010
Project Title:	Chuck's Boots	Applicant:	
Project Address:	346 SW BLUE PKWY, LEES SUMMIT, MO 64063		CATENACCI CONSTRUCTION LLC
Location:			14694 S RENE ST
Type of Work:	Change of Tenant		OLATHE, KS 66062
Occupancy Group:			
Description:	Tenant finishMechanical work will be under separate permit		

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Brian Austerman

Approved

1. Fire Department- IFC 2006 2307.2.1 Shelf storage.

Shelf storage greater than 12 feet (3658 mm) but less than 15 feet (4572 mm) in height shall be in accordance with the fire protection requirements set forth in NFPA 13. Shelf storage 15 feet (4572 mm) or more in height shall be protected in an approved manner with special fire protection, such as in-rack sprinklers.

ACTION REQUIRED: STORAGE SHALL NOT EXCEED 12' VERIFIED AT INSPECTION

2. Fire Department- IFC 2006 504.2 Maintenance of exterior doors and openings.

Exterior doors and their function shall not be eliminated without prior approval. Exterior doors that have been rendered nonfunctional and that retain a functional door exterior appearance shall have a sign affixed to the exterior side of the door with the words THIS DOOR BLOCKED. The sign shall consist of letters having a principal stroke of not less than 0.75 inch (19.1 mm) wide and at least 6 inches (152 mm) high on a contrasting background. Required fire department access doors shall not be obstructed or eliminated. Exit and exit access doors shall comply with Chapter 10. Access doors for high-piled combustible storage shall comply with Section 2306.6.1.

ACTION REQUIRED: BLOCKED DOORS SHALL BE MARKED AS SHOWN ABOVE, VERIFIED AT INSPECTION

3. Fire Department- IFC 2006 907.12 Duct smoke detectors.

Duct smoke detectors shall be connected to the building's fire alarm control panel when a fire alarm system is provided. Activation of a duct smoke detector shall initiate a visible and audible supervisory signal at a constantly attended location. Duct smoke detectors shall not be used as a substitute for required open area detection.

Exceptions:

1. The supervisory signal at a constantly attended location is not required where duct smoke detectors activate the building's alarm notification appliances.

2. In occupancies not required to be equipped with a fire alarm system, actuation of a smoke detector shall activate a visible and an audible signal in an approved location. Smoke detector trouble conditions shall activate a visible or audible signal in an approved location and shall be identified as air duct detector trouble.

ACTION REQUIRED: IF THE BUILDING HAS NO ALARM SYSTEM A REMOTE ANNUNCIATOR MUST BE INSTALLED TO SIGNAL DUCT DETECTOR ACTIVATION AND PROVIDE FOR A REMOTE TEST

4. Fire Department- 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED: IF AN ALARM SYSTEM IS TO BE INSTALLED PROVIDE CONSTRUCTION DOCUMENTS FOR THE ALARM SYSTEM TO THE FIRE DEPARTMENT FOR APPROVAL

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.