

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

PLAN REVIEW CONDITIONS

February 25, 2011

H2B Architects
1800 Baltimore
Kansas City, MO 64108

Permit No: PRCOM20110060
Project Title: Massage heights
Project Address: 970 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086
Parcel Number: 51700033300000000
Location: SUMMIT FAIR LOTS 22A & 24A---LOT 22A
Type of Work: New Tenant Finish
Occupancy Group: Business
Description: Massage parlor tenant finish

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

1. 2006 IBC 1210.2 - Walls. Walls within 2 feet of urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of 4 feet above the floor, and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture. Exceptions: 1. Dwelling units and sleeping units. 2. Toilet rooms that are not accessible to the public and which have not more than one water closet. Accessories such as grab bars, towel bars, paper dispensers and soap dishes, provided on or within walls, shall be installed and sealed to protect structural elements from moisture.

Action required - The wall elevations for the restroom shows the tile extending 3 feet above the floor at this location. Make needed corrections.,

2. ICC/ANSI A117.1 2003 804.6.6 - Refrigerator/Freezer. Combination refrigerators and freezers shall have at least 50 percent of the freezer compartment shelves, including the bottom of the freezer, 54 inches maximum above the floor when the shelves are installed at the maximum heights possible in the compartment. A clear floor space, positioned for a parallel approach to the space dedicated to a refrigerator/freezer, shall be provided. The centerline of the clear floor space shall be offset 24 inches maximum from the centerline of the dedicated space.

Action required - This comment is for information purposes.,

3. Mechanical, electrical and plumbing plans sealed by an engineer licensed in the State of Missouri have not been provided.

Action required - Provide sealed plans as well as specifications for the mechanical, electrical and plumbing work.,

4. ICC/ANSI A117.1 2003 404.2.3 - Maneuvering Clearance at Doors. Minimum maneuvering clearances at doors shall comply with Section 404.2.3 and shall include the full clear opening width of the doorway.

Action required - It does not appear that the required clearance on the pull side of the restroom doors is being met. The plans are not to scale. Make needed corrections.,

5. The door schedule does not indicate which doors, if any, are equipped with closures.

Action required - Please provide additional information as this can effect required clearances at doors.,

_____ Approved to issue per the listed conditions.

_____ Do not issue per the listed conditions.

_____ Approved to construct foundation only per the listed conditions.

_____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.